

TEST REPORT



Report number

23.01073

Start of test

21 February 2024

End of test

2 October 2024

Date report

26-11-2024 rev A 31-01-2025

Applicant

Aluprof SA
ul. Warszawska 153
P- 43-300 Bielsko-Biala
Poland

bezoekadres
Poppenbouwing 56
4191 NZ Geldermalsen

postadres
Postbus 202
4190 CE Geldermalsen

T +31 (0)88 244 01 00
F +31 (0)88 244 01 01
E info@skgikob.nl
I www.skgikob.nl

Size report

This report consists of 22 pages (including appendices)

Subject

Determination of the

- Resistance to repeated opening and closing according EN 1191
- Operating forces according EN 12046-2

of an aluminium, inwards opening door with sizes W x H: 1459 x 2960 mm, constructed from the profile system: Aluprof MB-86N

Inspector

R. Jonkergouw
J. van de Wetering

Technical manager

dr. ir. A. van Beek

Conclusion

The door of Aluprof SA
meets the classification as hereby mentioned:

- Mechanical durability according EN 12400
- Operating forces according EN 12217

Class

8
2